

**RECORD OF WORKS CARRIED OUT BY PARISH LENGTHSMAN**

Date	Description of work carried out
<p><u>Roads</u> <u>Account</u> <u>January</u> <u>2014</u></p>	<p><u>B4347</u> <u>Westwood Trading Estate - notified defect Ref EHGP/Parish Clerk</u> Clear grid and clean out road gulley - rod to main drainage pipe. Clear drainage trenches to ditch and reform leads. Clear culvert entry point. Check ditches to Village hall. Clear all road gulleys and side entry gulleys to village hall area. Clear pipe drains in kerb and road to field - see defect sheet.</p> <p><u>Garage area - notified defect Ref EHGP/Parish Clerk</u> Clear all side entry gulleys - rod to main drainage pipe. Clear all road gulley grids and sumps.</p> <p><u>Rosslyn</u> Clear out road gulleys at drive entrance - see defect sheet</p> <p><u>The Maples</u> Cleared road gulleys at drive entrance - see defect sheet</p> <p><u>Gateway opposite Rosslyn drive.</u> Field entrance drainage system grid seems to be blocked not allowing water into ditch - see defect sheet</p> <p><u>Mortimer Cottage</u> Cleaned out side entry gulleys. Rod to main drainage pipe - see defect sheet.</p> <p><u>Ty-Bony</u> Cleaned out road gulley - see defect sheet</p> <p><u>From Ty Bony to junction with C1213</u> Clear grids and clean out all road gulleys. Clean out all side entry gulleys. Clear pipe drains and grids at bridge on junction.</p> <p><u>C1213</u> <u>Doctors surgery area - notified defect Ref EHGP/Parish Clerk</u> Clean out road gulleys. Cleanout junction pip in footway. Rod connecting pipes - see defect sheet</p> <p><u>From doctors surgery to Old Malt House area.</u> Clear out all road gulleys. Clear side entry gulleys. Clear pipe drains through bridge wall. Rod all connecting pipes.</p> <p><u>General</u> Collect litter and rubbish from all areas worked.</p>

## Defect Sheet

B4347

Westwood Trading Estate

The ditches on the offside of the road up to the village hall have silted up above the entry/exit to culvert pipes where the road gulley drain pipes feed into the ditches. The silts in covering the exit points.

Action - Hereford Highways/BBLP to visit or local team to cost up clearance program.

B4347

Rossllyn

Connecting pipes to main drain is blocked and we are unable to rod clear.

Action - Local team to attend with jetting unit - please confirm.

Maples

Connecting pipes for gulleys and main pipe under road to pit area blocked. Unable to rod clear.

Action - Local team to attend with jetter unit - please confirm.

B4347

Gateway opposite Rossllyn Drive.

Landowner to be approached to arrange clearing of grid and ensure the ditch and headwall is clear.

Mortimers Cottage

Connecting pipes for gulleys are blocked. Unable to clear with rods.

action - Local team to attend with jetter unit - please confirm .

B4347

Ty Bony

Road gulley connecting pipes blocked Unable to rod clear.

Action - Local team to attend with jetting unit - please confirm.

C1213

Doctors surgery area.

The main pipe from the pit in footway to outlet in river is partially blocked reducing drainage from a low area in the road.

Action - due to the size of the main pipe above 9" we may have difficulty in clearing this pipe with our jetter. It may be worth trying if we are in the area working on the other jetter jobs. If we are unable to clear this pipe we will defect for BBLP.

N.B. We have defected the critical blockages on today's visit. However I must note in general all the gulleys on these roads attended on today's visit should be jetted out to help reduce the severe flooding local residents have been subjected to recently.

The drainage work would also have a significant benefit in helping to improve clearance of water from the area and should have priority listing, As the group parish covers a large area other than the Ewyas Harold Village the parish council could consider scheduling maintenance visits to these other areas so we can draw up a complete list of defects for the council to view and prioritise.